

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 26)**

Water Level of the accumulated water (at 7:00 on September 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,188 mm (36 mm decrease since 16:00 on September 25)	O.P.+ 2,955 mm (16 mm increase since 16:00 on September 25)	—
	Water level of Turbine Building	O.P.+ 2,950 mm (6 mm increase since 16:00 on September 25)	O.P.+ 3,174 mm (30 mm decrease since 16:00 on September 25)	O.P.+ 2,853 mm (22 mm increase since 16:00 on September 25)	O.P.+ 2,786 mm (15 mm increase since 16:00 on September 25)
	Water level of Reactor Building	O.P.+ 4,060 mm (3 mm increase since 16:00 on September 25)	O.P.+ 3,253 mm (26 mm decrease since 16:00 on September 25)	O.P.+ 2,906 mm (25 mm increase since 16:00 on September 25)	O.P.+ 2,792 mm (7 mm increase since 16:00 on September 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,745 mm (Increase from initial level:4,962 mm, 4 mm increase since 16:00 on September 25) O.P.+ 2,304 mm (Increase from initial level:3,030 mm, 45 mm decrease since 16:00 on September 25) O.P.+ 4,278 mm (Water level from floor:482 mm, 2 mm increase since 16:00 on September 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:56 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on September 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. * At 8:23 AM on September 26, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.