

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 30)

Water Level of the accumulated water (at 16:00 on September 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,951 mm (18 mm decrease since 7:00 on September 30)	O.P.+ 3,063 mm (12 mm increase since 7:00 on September 30)	—
	Water level of Turbine Building	O.P.+ 2,786 mm (202 mm decrease since 7:00 on September 30)	O.P.+ 2,969 mm (16 mm decrease since 7:00 on September 30)	O.P.+ 2,967 mm (9 mm increase since 7:00 on September 30)	O.P.+ 2,886 mm (8 mm increase since 7:00 on September 30)
	Water level of Reactor Building	O.P.+ 3,927 mm (16 mm decrease since 7:00 on September 30)	O.P.+ 3,044 mm (17 mm decrease since 7:00 on September 30)	O.P.+ 3,026 mm (9 mm increase since 7:00 on September 30)	O.P.+ 2,884 mm (10 mm increase since 7:00 on September 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,767 mm (Increase from initial level:4,984 mm, 2 mm increase since 7:00 on September 30) O.P.+ 2,038 mm (Increase from initial level:2,764 mm, 30 mm decrease since 7:00 on September 30) O.P.+ 4,278 mm (Water level from floor:482 mm, 1 mm increase since 7:00 on September 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 10:20 on September 30 to 17:42 on September 30)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:56 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:52 on September 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.