

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 3)**

Water Level of the accumulated water (at 7:00 on October 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,857 mm (14 mm decrease since 16:00 on October 2)	O.P.+ 3,138 mm (25 mm increase since 16:00 on October 2)	—
	Water level of Turbine Building	O.P.+ 2,753 mm (13 mm increase since 16:00 on October 2)	O.P.+ 2,885 mm (14 mm decrease since 16:00 on October 2)	O.P.+ 3,055 mm (27 mm increase since 16:00 on October 2)	O.P.+ 2,955 mm (21 mm increase since 16:00 on October 2)
	Water level of Reactor Building	O.P.+ 4,026 mm (82 mm increase since 16:00 on October 2)	O.P.+ 2,969 mm (28 mm decrease since 16:00 on October 2)	O.P.+ 3,122 mm (23 mm increase since 16:00 on October 2)	O.P.+ 2,951 mm (16 mm increase since 16:00 on October 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,781 mm (Increase from initial level:4,998 mm, 3 mm increase since 16:00 on October 2) O.P.+ 1,843 mm (Increase from initial level:2,569 mm, 44 mm decrease since 16:00 on October 2) O.P.+ 4,279 mm (Water level from floor:483 mm, 1 mm increase since 16:00 on October 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:56 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:52 on September 26   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.