

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 3)**

Water Level of the accumulated water (at 16:00 on October 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,846 mm (11 mm decrease since 7:00 on October 3)	O.P.+ 3,146 mm (8 mm increase since 7:00 on October 3)	—
	Water level of Turbine Building	O.P.+ 2,760 mm (7 mm increase since 7:00 on October 3)	O.P.+ 2,877 mm (8 mm decrease since 7:00 on October 3)	O.P.+ 3,063 mm (8 mm increase since 7:00 on October 3)	O.P.+ 2,967 mm (12 mm increase since 7:00 on October 3)
	Water level of Reactor Building	O.P.+ 4,038 mm (12 mm increase since 7:00 on October 3)	O.P.+ 2,954 mm (15 mm decrease since 7:00 on October 3)	O.P.+ 3,130 mm (8 mm increase since 7:00 on October 3)	O.P.+ 2,959 mm (8 mm increase since 7:00 on October 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,783 mm (Increase from initial level:5,000 mm, 2 mm increase since 7:00 on October 3) O.P.+ 1,990 mm (Increase from initial level:2,716 mm, 147 mm increase since 7:00 on October 3) O.P.+ 4,279 mm (Water level from floor:483 mm, No change since 7:00 on October 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:56 on September 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:22 on September 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on October 3   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* The second cesium absorption apparatus was stopped at 8:24 on September 4 due to a filter cleaning. After completion of it, it was restarted at 12:50. We confirmed normal flow at 13:20. * Water transfer was done from the well point of Unit 2 turbine building to Unit 2 turbine building from 14:56 September 3 to 12:55 September 4. We restarted it at 14:21. * Water transfer from the vertical duct B to Unit 2 turbine building from 13:02 to 14:05 on September 4				

※ For quick publication of the data of water level, values are provided as reference values.