

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 8)**

Water Level of the accumulated water (at 7:00 on October 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,151 mm (43 mm increase since 16:00 on October 7)	O.P.+ 3,049 mm (18 mm decrease since 16:00 on October 7)	—
	Water level of Turbine Building	O.P.+ 2,837 mm (10 mm increase since 16:00 on October 7)	O.P.+ 3,144 mm (35 mm increase since 16:00 on October 7)	O.P.+ 2,882 mm (20 mm decrease since 16:00 on October 7)	O.P.+ 2,897 mm (19 mm decrease since 16:00 on October 7)
	Water level of Reactor Building	O.P.+ 4,064 mm (12 mm increase since 16:00 on October 7)	O.P.+ 3,202 mm (35 mm increase since 16:00 on October 7)	O.P.+ 2,943 mm (24 mm decrease since 16:00 on October 7)	O.P.+ 2,916 mm (16 mm decrease since 16:00 on October 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,807 mm (Increase from initial level:5,024 mm, 3 mm increase since 16:00 on October 7) O.P.+ 2,202 mm (Increase from initial level:2,928 mm, 45 mm increase since 16:00 on October 7) O.P.+ 4,279 mm (Water level from floor:483 mm, No change since 16:00 on October 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on October 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.