

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 8)**

Water Level of the accumulated water (at 16:00 on October 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,180 mm (29 mm increase since 7:00 on October 8)	O.P.+ 3,037 mm (12 mm decrease since 7:00 on October 8)	—
	Water level of Turbine Building	O.P.+ 2,843 mm (6 mm increase since 7:00 on October 8)	O.P.+ 3,159 mm (15 mm increase since 7:00 on October 8)	O.P.+ 2,868 mm (14 mm decrease since 7:00 on October 8)	O.P.+ 2,886 mm (11 mm decrease since 7:00 on October 8)
	Water level of Reactor Building	O.P.+ 4,073 mm (9 mm increase since 7:00 on October 8)	O.P.+ 3,231 mm (29 mm increase since 7:00 on October 8)	O.P.+ 2,929 mm (14 mm decrease since 7:00 on October 8)	O.P.+ 2,906 mm (10 mm decrease since 7:00 on October 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,810 mm (Increase from initial level:5,027 mm, 3 mm increase since 7:00 on October 8) O.P.+ 2,233 mm (Increase from initial level:2,959 mm, 31 mm increase since 7:00 on October 8) O.P.+ 4,279 mm (Water level from floor:483 mm, No change since 7:00 on October 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on October 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.