

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 9)**

Water Level of the accumulated water (at 7:00 on October 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,231 mm (51 mm increase since 16:00 on October 8)	O.P.+ 3,016 mm (21 mm decrease since 16:00 on October 8)	—
	Water level of Turbine Building	O.P.+ 2,853 mm (10 mm increase since 16:00 on October 8)	O.P.+ 3,210 mm (51 mm increase since 16:00 on October 8)	O.P.+ 2,844 mm (24 mm decrease since 16:00 on October 8)	O.P.+ 2,865 mm (21 mm decrease since 16:00 on October 8)
	Water level of Reactor Building	O.P.+ 4,089 mm (16 mm increase since 16:00 on October 8)	O.P.+ 3,274 mm (43 mm increase since 16:00 on October 8)	O.P.+ 2,906 mm (23 mm decrease since 16:00 on October 8)	O.P.+ 2,890 mm (16 mm decrease since 16:00 on October 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,813 mm (Increase from initial level:5,030 mm, 3 mm increase since 16:00 on October 8) O.P.+ 2,282 mm (Increase from initial level:3,008 mm, 49 mm increase since 16:00 on October 8) O.P.+ 4,279 mm (Water level from floor:483 mm, No change since 16:00 on October 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on October 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.