

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 9)**

Water Level of the accumulated water (at 16:00 on October 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,259 mm (28 mm increase since 7:00 on October 9)	O.P.+ 3,005 mm (11 mm decrease since 7:00 on October 9)	—
	Water level of Turbine Building	O.P.+ 2,858 mm (5 mm increase since 7:00 on October 9)	O.P.+ 3,237 mm (27 mm increase since 7:00 on October 9)	O.P.+ 2,833 mm (11 mm decrease since 7:00 on October 9)	O.P.+ 2,854 mm (11 mm decrease since 7:00 on October 9)
	Water level of Reactor Building	O.P.+ 4,099 mm (10 mm increase since 7:00 on October 9)	O.P.+ 3,300 mm (26 mm increase since 7:00 on October 9)	O.P.+ 2,892 mm (14 mm decrease since 7:00 on October 9)	O.P.+ 2,880 mm (10 mm decrease since 7:00 on October 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,815 mm (Increase from initial level:5,032 mm, 2 mm increase since 7:00 on October 9) O.P.+ 2,308 mm (Increase from initial level:3,034 mm, 26 mm increase since 7:00 on October 9) O.P.+ 4,279 mm (Water level from floor:483 mm, No change since 7:00 on October 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on October 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

For quick publication of the data of water level, values are provided as reference values.