

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 10)**

Water Level of the accumulated water (at 7:00 on October 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,303 mm (44 mm increase since 16:00 on October 9)	O.P.+ 2,988 mm (17 mm decrease since 16:00 on October 9)	—
	Water level of Turbine Building	O.P.+ 2,868 mm (10 mm increase since 16:00 on October 9)	O.P.+ 3,275 mm (38 mm increase since 16:00 on October 9)	O.P.+ 2,810 mm (23 mm decrease since 16:00 on October 9)	O.P.+ 2,834 mm (20 mm decrease since 16:00 on October 9)
	Water level of Reactor Building	O.P.+ 4,114 mm (15 mm increase since 16:00 on October 9)	O.P.+ 3,335 mm (35 mm increase since 16:00 on October 9)	O.P.+ 2,870 mm (22 mm decrease since 16:00 on October 9)	O.P.+ 2,864 mm (16 mm decrease since 16:00 on October 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,818 mm (Increase from initial level:5,035 mm, 3 mm increase since 16:00 on October 9) O.P.+ 2,358 mm (Increase from initial level:3,084 mm, 50 mm increase since 16:00 on October 9) O.P.+ 4,280 mm (Water level from floor:484 mm, 1 mm increase since 16:00 on October 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:20 on October 10 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. * At 8:20 AM on October 10, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.