

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 11)

Water Level of the accumulated water (at 16:00 on October 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,215 mm (30 mm decrease since 7:00 on October 11)	O.P.+ 2,985 mm (3 mm increase since 7:00 on October 11)	—
	Water level of Turbine Building	O.P.+ 2,889 mm (7 mm increase since 7:00 on October 11)	O.P.+ 3,200 mm (23 mm decrease since 7:00 on October 11)	O.P.+ 2,871 mm (11 mm increase since 7:00 on October 11)	O.P.+ 2,818 mm (2 mm increase since 7:00 on October 11)
	Water level of Reactor Building	O.P.+ 4,128 mm (No change since 7:00 on October 11)	O.P.+ 3,289 mm (22 mm decrease since 7:00 on October 11)	O.P.+ 2,927 mm (12 mm increase since 7:00 on October 11)	O.P.+ 2,834 mm (6 mm decrease since 7:00 on October 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,826 mm (Increase from initial level:5,043 mm, 2 mm increase since 7:00 on October 11) O.P.+ 2,550 mm (Increase from initial level:3,276 mm, 22 mm increase since 7:00 on October 11) O.P.+ 4,280 mm (Water level from floor:484 mm, No change since 7:00 on October 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on October 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:15 on October 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.