

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 16)**

Water Level of the accumulated water (at 7:00 on October 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,020 mm (16 mm increase since 16:00 on October 15)	O.P.+ 3,078 mm (38 mm increase since 16:00 on October 15)	—
	Water level of Turbine Building	O.P.+ 2,963 mm (25 mm increase since 16:00 on October 15)	O.P.+ 3,025 mm (10 mm increase since 16:00 on October 15)	O.P.+ 2,969 mm (42 mm increase since 16:00 on October 15)	O.P.+ 2,883 mm (17 mm increase since 16:00 on October 15)
	Water level of Reactor Building	O.P.+ 4,162 mm (142 mm increase since 16:00 on October 15)	O.P.+ 3,102 mm (No change since 16:00 on October 15)	O.P.+ 2,993 mm (No change since 16:00 on October 15)	O.P.+ 2,918 mm (53 mm increase since 16:00 on October 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,851 mm (Increase from initial level:5,068 mm, 4 mm increase since 16:00 on October 15) O.P.+ 2,906 mm (Increase from initial level:3,632 mm, 55 mm increase since 16:00 on October 15) O.P.+ 4,278 mm (Water level from floor:482 mm, 1 mm decrease since 16:00 on October 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on October 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:15 on October 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.