

Revised Version

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 18)**

* The underlined part has corrected on October 18, 2013.

Water Level of the accumulated water (at 7:00 on October 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,151 mm (13 mm increase since 16:00 on October 17)	O.P.+ 3,167 mm (13 mm increase since 16:00 on October 17)	—
	Water level of Turbine Building	O.P.+ 3,233 mm (26 mm increase since 16:00 on October 17)	O.P.+ 3,138 mm (13 mm increase since 16:00 on October 17)	O.P.+ 3,051 mm (12 mm increase since 16:00 on October 17)	O.P.+ 2,975 mm (19 mm increase since 16:00 on October 17)
	Water level of Reactor Building	O.P.+ 4,637 mm (No change since 16:00 on October 17)	O.P.+ 3,225 mm (23 mm increase since 16:00 on October 17)	O.P.+ 3,128 mm (12 mm increase since 16:00 on October 17)	O.P.+ 2,967 mm (14 mm increase since 16:00 on October 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,860 mm (Increase from initial level:5,077 mm, 2 mm increase since 16:00 on October 17) O.P.+ 3,556 mm (Increase from initial level:4,282 mm, 66 mm increase since 16:00 on October 17) O.P.+ 4,281 mm (Water level from floor:485 mm, No change since 16:00 on October 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on October 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:26 on October 4)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:46 on October 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:27 AM on October 17, we temporarily stopped the Second Cesium Adsorption Apparatus (SARRY) for vessel replacement. At 5:22 PM on the same day, the apparatus was restarted after the vessel replacement, and the steady flow rate was achieved at 6:46 PM on the same day. * <u>Water transfer is done from the well point at the east side of Unit 2 turbine building to Unit 2 turbine building from 13:33 September 7.</u>				

※ For quick publication of the data of water level, values are provided as reference values.