

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 21)**

Water Level of the accumulated water (at 7:00 on October 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,340 mm (129 mm increase since 16:00 on October 20)	O.P.+ 3,306 mm (77 mm increase since 16:00 on October 20)	—
	Water level of Turbine Building	O.P.+ 3,030 mm (304 mm increase since 16:00 on October 20)	O.P.+ 3,296 mm (107 mm increase since 16:00 on October 20)	O.P.+ 3,202 mm (84 mm increase since 16:00 on October 20)	O.P.+ 3,072 mm (42 mm increase since 16:00 on October 20)
	Water level of Reactor Building	O.P.+ 4,824 mm (261 mm increase since 16:00 on October 20)	O.P.+ 3,383 mm (97 mm increase since 16:00 on October 20)	O.P.+ 3,201 mm (No change since 16:00 on October 20)	O.P.+ 3,099 mm (76 mm increase since 16:00 on October 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,878 mm (Increase from initial level:5,095 mm, 4 mm increase since 16:00 on October 20) O.P.+ 3,361 mm (Increase from initial level:4,087 mm, 123 mm decrease since 16:00 on October 20) O.P.+ 4,286 mm (Water level from floor:490 mm, 3 mm increase since 16:00 on October 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on October 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:08 on October 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:46 on October 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.