

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 22)**

Water Level of the accumulated water (at 7:00 on October 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,420 mm (41 mm increase since 16:00 on October 21)	O.P.+ 3,334 mm (5 mm increase since 16:00 on October 21)	—
	Water level of Turbine Building	O.P.+ 3,097 mm (37 mm increase since 16:00 on October 21)	O.P.+ 3,365 mm (34 mm increase since 16:00 on October 21)	O.P.+ 3,216 mm (7 mm decrease since 16:00 on October 21)	O.P.+ 3,117 mm (26 mm increase since 16:00 on October 21)
	Water level of Reactor Building	O.P.+ 4,885 mm (9 mm increase since 16:00 on October 21)	O.P.+ 3,446 mm (36 mm increase since 16:00 on October 21)	O.P.+ 3,310 mm (4 mm decrease since 16:00 on October 21)	O.P.+ 3,100 mm (13 mm increase since 16:00 on October 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,036 mm (Increase from initial level:5,253 mm, 156 mm increase since 16:00 on October 21) O.P.+ 3,016 mm (Increase from initial level:3,742 mm, 278 mm decrease since 16:00 on October 21) O.P.+ 4,287 mm (Water level from floor:491 mm, 1 mm increase since 16:00 on October 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 18:03 on October 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:08 on October 20)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:21 on October 22 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 7:21 AM on October 22, we temporarily stopped the Second Cesium Adsorption Apparatus (SARRY) for vessel replacement. - Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.