

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 23)**

Water Level of the accumulated water (at 7:00 on October 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,419 mm (6 mm decrease since 16:00 on October 22)	O.P.+ 3,312 mm (8 mm decrease since 16:00 on October 22)	—
	Water level of Turbine Building	O.P.+ 3,153 mm (35 mm increase since 16:00 on October 22)	O.P.+ 3,363 mm (5 mm decrease since 16:00 on October 22)	O.P.+ 3,165 mm (30 mm decrease since 16:00 on October 22)	O.P.+ 3,128 mm (1 mm increase since 16:00 on October 22)
	Water level of Reactor Building	O.P.+ 4,859 mm (16 mm decrease since 16:00 on October 22)	O.P.+ 3,462 mm (3 mm increase since 16:00 on October 22)	O.P.+ 3,264 mm (28 mm decrease since 16:00 on October 22)	O.P.+ 3,118 mm (9 mm increase since 16:00 on October 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,297 mm (Increase from initial level:5,514 mm, 159 mm increase since 16:00 on October 22) O.P.+ 3,393 mm (Increase from initial level:4,119 mm, 30 mm increase since 16:00 on October 22) O.P.+ 4,288 mm (Water level from floor:492 mm, 1 mm increase since 16:00 on October 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 18:03 on October 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:52 on October 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.