

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 24)**

Water Level of the accumulated water (at 7:00 on October 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,376 mm (43 mm decrease since 16:00 on October 23)	O.P.+ 3,337 mm (29 mm increase since 16:00 on October 23)	—
	Water level of Turbine Building	O.P.+ 3,204 mm (32 mm increase since 16:00 on October 23)	O.P.+ 3,327 mm (36 mm decrease since 16:00 on October 23)	O.P.+ 3,224 mm (65 mm increase since 16:00 on October 23)	O.P.+ 3,130 mm (6 mm increase since 16:00 on October 23)
	Water level of Reactor Building	O.P.+ 4,849 mm (No change since 16:00 on October 23)	O.P.+ 3,437 mm (22 mm decrease since 16:00 on October 23)	O.P.+ 3,307 mm (58 mm increase since 16:00 on October 23)	O.P.+ 3,115 mm (1 mm decrease since 16:00 on October 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,163 mm (Increase from initial level:5,380 mm, 162 mm decrease since 16:00 on October 23) O.P.+ 3,381 mm (Increase from initial level:4,107 mm, 7 mm decrease since 16:00 on October 23) O.P.+ 4,288 mm (Water level from floor:492 mm, 1 mm increase since 16:00 on October 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 17:39 on October 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on October 23 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 17:52 on October 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.