

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 25)**

Water Level of the accumulated water (at 7:00 on October 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,295 mm (52 mm decrease since 16:00 on October 24)	O.P.+ 3,404 mm (40 mm increase since 16:00 on October 24)	—
	Water level of Turbine Building	O.P.+ 3,249 mm (28 mm increase since 16:00 on October 24)	O.P.+ 3,259 mm (44 mm decrease since 16:00 on October 24)	O.P.+ 3,300 mm (40 mm increase since 16:00 on October 24)	O.P.+ 3,165 mm (24 mm increase since 16:00 on October 24)
	Water level of Reactor Building	O.P.+ 4,767 mm (32 mm decrease since 16:00 on October 24)	O.P.+ 3,377 mm (37 mm decrease since 16:00 on October 24)	O.P.+ 3,394 mm (45 mm increase since 16:00 on October 24)	O.P.+ 3,136 mm (14 mm increase since 16:00 on October 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,887 mm (Increase from initial level:5,104 mm, 182 mm decrease since 16:00 on October 24) O.P.+ 3,369 mm (Increase from initial level:4,095 mm, 7 mm decrease since 16:00 on October 24) O.P.+ 4,289 mm (Water level from floor:493 mm, 1 mm increase since 16:00 on October 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 17:39 on October 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on October 23 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 17:52 on October 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.