

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 28)**

Water Level of the accumulated water (at 7:00 on October 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,286 mm (10 mm decrease since 16:00 on October 27)	O.P.+ 3,340 mm (20 mm decrease since 16:00 on October 27)	—
	Water level of Turbine Building	O.P.+ 3,383 mm (24 mm increase since 16:00 on October 27)	O.P.+ 3,250 mm (8 mm decrease since 16:00 on October 27)	O.P.+ 3,170 mm (24 mm decrease since 16:00 on October 27)	O.P.+ 3,160 mm (12 mm decrease since 16:00 on October 27)
	Water level of Reactor Building	O.P.+ 4,666 mm (51 mm decrease since 16:00 on October 27)	O.P.+ 3,337 mm (11 mm decrease since 16:00 on October 27)	O.P.+ 3,265 mm (26 mm decrease since 16:00 on October 27)	O.P.+ 3,152 mm (11 mm decrease since 16:00 on October 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,844 mm (Increase from initial level:5,061 mm, 9 mm increase since 16:00 on October 27) O.P.+ 3,412 mm (Increase from initial level:4,138 mm, 21 mm increase since 16:00 on October 27) O.P.+ 4,290 mm (Water level from floor:494 mm, No change since 16:00 on October 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:58 on October 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on October 23 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:18 on October 28 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. * At 8:18 AM on October 28, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.