

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 29)**

Water Level of the accumulated water (at 16:00 on October 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,257 mm (8 mm decrease since 7:00 on October 29)	O.P.+ 3,300 mm (14 mm decrease since 7:00 on October 29)	—
	Water level of Turbine Building	O.P.+ 3,430 mm (13 mm increase since 7:00 on October 29)	O.P.+ 3,225 mm (7 mm decrease since 7:00 on October 29)	O.P.+ 3,118 mm (13 mm decrease since 7:00 on October 29)	O.P.+ 3,128 mm (10 mm decrease since 7:00 on October 29)
	Water level of Reactor Building	O.P.+ 4,565 mm (29 mm decrease since 7:00 on October 29)	O.P.+ 3,320 mm (4 mm decrease since 7:00 on October 29)	O.P.+ 3,213 mm (14 mm decrease since 7:00 on October 29)	O.P.+ 3,125 mm (7 mm decrease since 7:00 on October 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,875 mm (Increase from initial level:5,092 mm, 11 mm increase since 7:00 on October 29) O.P.+ 3,586 mm (Increase from initial level:4,312 mm, 6 mm increase since 7:00 on October 29) O.P.+ 4,291 mm (Water level from floor:495 mm, 1 mm increase since 7:00 on October 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:58 on October 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on October 23 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:55 on October 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. *From 9:12 to 16:00 on Oct. 29, we transfered the accumulated water from the temporary tanks of Units 5 and 6 to F tank area at the north side of Unit 6.				

※ For quick publication of the data of water level, values are provided as reference values.