

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 31)**

Water Level of the accumulated water (at 7:00 on October 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,208 mm (21 mm decrease since 16:00 on October 30)	O.P.+ 3,251 mm (20 mm decrease since 16:00 on October 30)	—
	Water level of Turbine Building	O.P.+ 3,481 mm (19 mm increase since 16:00 on October 30)	O.P.+ 3,186 mm (17 mm decrease since 16:00 on October 30)	O.P.+ 3,060 mm (22 mm decrease since 16:00 on October 30)	O.P.+ 3,084 mm (17 mm decrease since 16:00 on October 30)
	Water level of Reactor Building	O.P.+ 4,460 mm (39 mm decrease since 16:00 on October 30)	O.P.+ 3,280 mm (20 mm decrease since 16:00 on October 30)	O.P.+ 3,156 mm (21 mm decrease since 16:00 on October 30)	O.P.+ 3,092 mm (11 mm decrease since 16:00 on October 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,929 mm (Increase from initial level:5,146 mm, 20 mm increase since 16:00 on October 30) O.P.+ 3,567 mm (Increase from initial level:4,293 mm, 8 mm decrease since 16:00 on October 30) O.P.+ 4,291 mm (Water level from floor:495 mm, No change since 16:00 on October 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:58 on October 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:50 on October 23 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:55 on October 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.