

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 5)**

Water Level of the accumulated water (at 7:00 on November 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,826 mm (71 mm decrease since 16:00 on November 4)	O.P.+ 3,341 mm (31 mm increase since 16:00 on November 4)	—
	Water level of Turbine Building	O.P.+ 3,355 mm (14 mm increase since 16:00 on November 4)	O.P.+ 2,862 mm (60 mm decrease since 16:00 on November 4)	O.P.+ 3,222 mm (33 mm increase since 16:00 on November 4)	O.P.+ 3,082 mm (20 mm increase since 16:00 on November 4)
	Water level of Reactor Building	O.P.+ 4,161 mm (45 mm decrease since 16:00 on November 4)	O.P.+ 2,980 mm (65 mm decrease since 16:00 on November 4)	O.P.+ 3,316 mm (37 mm increase since 16:00 on November 4)	O.P.+ 3,071 mm (18 mm increase since 16:00 on November 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,078 mm (Increase from initial level:4,295 mm, 192 mm decrease since 16:00 on November 4) O.P.+ 3,502 mm (Increase from initial level:4,228 mm, 10 mm decrease since 16:00 on November 4) O.P.+ 4,297 mm (Water level from floor:501 mm, No change since 16:00 on November 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:57 on November 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:53 on October 22)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 14:00 on November 1 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:55 on October 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.