

Revised Version

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 7)

Water Level of the accumulated water (at 7:00 on November 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,758 mm (23 mm decrease since 16:00 on November 6)	O.P.+ 3,306 mm (5 mm increase since 16:00 on November 6)	—
	Water level of Turbine Building	O.P.+ 3,392 mm (12 mm increase since 16:00 on November 6)	O.P.+ 2,804 mm (19 mm decrease since 16:00 on November 6)	O.P.+ 3,111 mm (15 mm decrease since 16:00 on November 6)	O.P.+ 3,083 mm (10 mm decrease since 16:00 on November 6)
	Water level of Reactor Building	O.P.+ 4,043 mm (32 mm decrease since 16:00 on November 6)	O.P.+ 2,911 mm (16 mm decrease since 16:00 on November 6)	O.P.+ 3,206 mm (17 mm decrease since 16:00 on November 6)	O.P.+ 3,081 mm (7 mm decrease since 16:00 on November 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,408 mm (Increase from initial level:4,625 mm, 229 mm increase since 16:00 on November 6) O.P.+ 3,293 mm (Increase from initial level:4,019 mm, 138 mm decrease since 16:00 on November 6) O.P.+ 4,299 mm (Water level from floor:503 mm, No change since 16:00 on November 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:05 on November 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:18 on November 7 Suspended *1 Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. *1 We initially announced that the 2nd Cesium Adsorption Apparatus (Sarry) was "in operation". However, we have corrected to "suspended", since backwash of filter has been conducted since 8:18 AM on November 7. (Corrected on November 7, 2013)				

※ For quick publication of the data of water level, values are provided as reference values.