

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 8)**

Water Level of the accumulated water (at 16:00 on November 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,716 mm (5 mm decrease since 7:00 on November 8)	O.P.+ 3,133 mm (7 mm decrease since 7:00 on November 8)	—
	Water level of Turbine Building	O.P.+ 3,239 mm (170 mm decrease since 7:00 on November 8)	O.P.+ 2,769 mm (6 mm decrease since 7:00 on November 8)	O.P.+ 3,078 mm (7 mm decrease since 7:00 on November 8)	O.P.+ 3,061 mm (5 mm decrease since 7:00 on November 8)
	Water level of Reactor Building	O.P.+ 3,879 mm (18 mm decrease since 7:00 on November 8)	O.P.+ 2,871 mm (12 mm decrease since 7:00 on November 8)	O.P.+ 3,171 mm (9 mm decrease since 7:00 on November 8)	O.P.+ 3,062 mm (5 mm decrease since 7:00 on November 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,858 mm (Increase from initial level:5,075 mm, 138 mm increase since 7:00 on November 8) O.P.+ 3,008 mm (Increase from initial level:3,734 mm, 91 mm decrease since 7:00 on November 8) O.P.+ 4,301 mm (Water level from floor:505 mm, No change since 7:00 on November 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 10:15 on November 8)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:05 on November 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on November 7   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 13:33 on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.