

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 11)**

Water Level of the accumulated water (at 16:00 on November 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,920 mm (42 mm increase since 7:00 on November 11)	O.P.+ 3,074 mm (7 mm decrease since 7:00 on November 11)	—
	Water level of Turbine Building	O.P.+ 3,217 mm (6 mm increase since 7:00 on November 11)	O.P.+ 2,947 mm (38 mm increase since 7:00 on November 11)	O.P.+ 3,010 mm (9 mm decrease since 7:00 on November 11)	O.P.+ 3,012 mm (2 mm increase since 7:00 on November 11)
	Water level of Reactor Building	O.P.+ 3,830 mm (6 mm increase since 7:00 on November 11)	O.P.+ 3,015 mm (29 mm increase since 7:00 on November 11)	O.P.+ 3,106 mm (6 mm decrease since 7:00 on November 11)	O.P.+ 3,014 mm (9 mm decrease since 7:00 on November 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,057 mm (Increase from initial level:5,274 mm, 4 mm increase since 7:00 on November 11) O.P.+ 2,421 mm (Increase from initial level:3,147 mm, 60 mm decrease since 7:00 on November 11) O.P.+ 4,306 mm (Water level from floor:510 mm, No change since 7:00 on November 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on November 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 13:33 on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.