## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 12)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on November 12)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,973 mm (5 mm increase since 7:00 on November 12)	O.P.+ 3,056 mm (5 mm decrease since 7:00 on November 12)	-
	Water level of Turbine Building	O.P.+ 3,233 mm (5 mm increase since 7:00 on November 12)	O.P.+ 2,991 mm (3 mm increase since 7:00 on November 12)	O.P.+ 3,011 mm (13 mm increase since 7:00 on November 12)	O.P.+ 2,982 mm (10 mm decrease since 7:00 on November 12)
	Water level of Reactor Building	O.P.+ 3,851 mm (7 mm increase since 7:00 on November 12)	O.P.+ 3,065 mm (2 mm increase since 7:00 on November 12)	O.P.+ 3,093 mm (5 mm increase since 7:00 on November 12)	O.P.+ 2,996 mm (8 mm decrease since 7:00 on November 12)
	Water level of each building in the Centralized Radiation Waste	Process Main Building	O.P.+ 4,061 mm (Increase from initial level:5,278 mm, 4 mm increase since 7:00 on November 12)		
		High Temperature Incinerator Building	O.P.+ 2,305 mm (Increase from initial level:3,031 mm, 20 mm decrease since 7:00 on November 12)		
Treatment Fac		On-site Bunker Building	O.P.+ 4,307 mm (Water level from floor:511 mm, 1 mm increase since 7:00 on November 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:15 on November 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	_
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:00 on November 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*From 9:54 on November 12, we reduced the number of accumulating water transferring pumps from 2 to 1, which we are using to transfer water from the Unit 3 turbine building basement to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building). * Since 13:33 on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

% For quick publication of the data of water level, values are provided as reference values.