

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 13)**

Water Level of the accumulated water (at 7:00 on November 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,927 mm (46 mm decrease since 16:00 on November 12)	O.P.+ 3,065 mm (9 mm increase since 16:00 on November 12)	—
	Water level of Turbine Building	O.P.+ 3,241 mm (8 mm increase since 16:00 on November 12)	O.P.+ 2,953 mm (38 mm decrease since 16:00 on November 12)	O.P.+ 3,038 mm (27 mm increase since 16:00 on November 12)	O.P.+ 2,980 mm (2 mm decrease since 16:00 on November 12)
	Water level of Reactor Building	O.P.+ 3,858 mm (7 mm increase since 16:00 on November 12)	O.P.+ 3,037 mm (28 mm decrease since 16:00 on November 12)	O.P.+ 3,120 mm (27 mm increase since 16:00 on November 12)	O.P.+ 2,988 mm (8 mm decrease since 16:00 on November 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,062 mm (Increase from initial level:5,279 mm, 1 mm increase since 16:00 on November 12) O.P.+ 2,304 mm (Increase from initial level:3,030 mm, 1 mm decrease since 16:00 on November 12) O.P.+ 4,308 mm (Water level from floor:512 mm, 1 mm increase since 16:00 on November 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:15 on November 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:18 on November 13 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.