

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 15)**

Water Level of the accumulated water (at 7:00 on November 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,823 mm (37 mm decrease since 16:00 on November 14)	O.P.+ 3,096 mm (11 mm increase since 16:00 on November 14)	—
	Water level of Turbine Building	O.P.+ 2,787 mm (473 mm decrease since 16:00 on November 14)	O.P.+ 2,863 mm (32 mm decrease since 16:00 on November 14)	O.P.+ 3,072 mm (11 mm increase since 16:00 on November 14)	O.P.+ 3,004 mm (7 mm increase since 16:00 on November 14)
	Water level of Reactor Building	O.P.+ 3,847 mm (5 mm decrease since 16:00 on November 14)	O.P.+ 2,943 mm (20 mm decrease since 16:00 on November 14)	O.P.+ 3,159 mm (10 mm increase since 16:00 on November 14)	O.P.+ 3,000 mm (7 mm increase since 16:00 on November 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,069 mm (Increase from initial level:5,286 mm, 2 mm increase since 16:00 on November 14) O.P.+ 2,516 mm (Increase from initial level:3,242 mm, 35 mm decrease since 16:00 on November 14) O.P.+ 4,363 mm (Water level from floor:567 mm, 2 mm increase since 16:00 on November 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 17:19 on November 14)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:15 on November 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:19 on November 13   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.