

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 18)**

Water Level of the accumulated water (at 16:00 on November 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,984 mm (34 mm increase since 7:00 on November 18)	O.P.+ 2,996 mm (2 mm decrease since 7:00 on November 18)	—
	Water level of Turbine Building	O.P.+ 2,693 mm (4 mm increase since 7:00 on November 18)	O.P.+ 3,002 mm (28 mm increase since 7:00 on November 18)	O.P.+ 2,961 mm (16 mm decrease since 7:00 on November 18)	O.P.+ 2,975 mm (10 mm decrease since 7:00 on November 18)
	Water level of Reactor Building	O.P.+ 3,855 mm (9 mm increase since 7:00 on November 18)	O.P.+ 3,063 mm (31 mm increase since 7:00 on November 18)	O.P.+ 3,051 mm (15 mm decrease since 7:00 on November 18)	O.P.+ 2,989 mm (6 mm decrease since 7:00 on November 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,082 mm (Increase from initial level:5,299 mm, 4 mm increase since 7:00 on November 18) O.P.+ 2,355 mm (Increase from initial level:3,081 mm, 15 mm decrease since 7:00 on November 18) O.P.+ 4,375 mm (Water level from floor:579 mm, 2 mm increase since 7:00 on November 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		— (to on)	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:19 on November 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 13:33 on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.