

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 20)**

Water Level of the accumulated water (at 7:00 on November 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,095 mm (39 mm increase since 16:00 on November 19)	O.P.+ 2,931 mm (21 mm decrease since 16:00 on November 19)	—
	Water level of Turbine Building	O.P.+ 2,710 mm (7 mm increase since 16:00 on November 19)	O.P.+ 3,092 mm (29 mm increase since 16:00 on November 19)	O.P.+ 2,900 mm (22 mm decrease since 16:00 on November 19)	O.P.+ 2,927 mm (19 mm decrease since 16:00 on November 19)
	Water level of Reactor Building	O.P.+ 3,894 mm (15 mm increase since 16:00 on November 19)	O.P.+ 3,157 mm (32 mm increase since 16:00 on November 19)	O.P.+ 2,983 mm (26 mm decrease since 16:00 on November 19)	O.P.+ 2,951 mm (15 mm decrease since 16:00 on November 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,088 mm (Increase from initial level:5,305 mm, 2 mm increase since 16:00 on November 19) O.P.+ 2,288 mm (Increase from initial level:3,014 mm, 25 mm decrease since 16:00 on November 19) O.P.+ 4,384 mm (Water level from floor:588 mm, 4 mm increase since 16:00 on November 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		— (to on)	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:19 on November 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.