

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 21)**

Water Level of the accumulated water (at 16:00 on November 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,204 mm (35 mm increase since 7:00 on November 21)	O.P.+ 2,883 mm (12 mm decrease since 7:00 on November 21)	—
	Water level of Turbine Building	O.P.+ 2,724 mm (5 mm increase since 7:00 on November 21)	O.P.+ 3,186 mm (29 mm increase since 7:00 on November 21)	O.P.+ 2,853 mm (14 mm decrease since 7:00 on November 21)	O.P.+ 2,888 mm (9 mm decrease since 7:00 on November 21)
	Water level of Reactor Building	O.P.+ 3,931 mm (9 mm increase since 7:00 on November 21)	O.P.+ 3,240 mm (21 mm increase since 7:00 on November 21)	O.P.+ 2,933 mm (13 mm decrease since 7:00 on November 21)	O.P.+ 2,915 mm (10 mm decrease since 7:00 on November 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,095 mm (Increase from initial level:5,312 mm, 2 mm increase since 7:00 on November 21) O.P.+ 2,416 mm (Increase from initial level:3,142 mm, 157 mm increase since 7:00 on November 21) O.P.+ 4,392 mm (Water level from floor:596 mm, 3 mm increase since 7:00 on November 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:23 on November 21   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*At 8:26 AM on November 21, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. After the washing work has completed, it started operation at 12:40 PM and reached constant flow at 1:23 PM. * Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.