

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 25)**

Water Level of the accumulated water (at 7:00 on November 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,040 mm (39 mm decrease since 16:00 on November 24)	O.P.+ 2,890 mm (9 mm increase since 16:00 on November 24)	—
	Water level of Turbine Building	O.P.+ 2,746 mm (3 mm increase since 16:00 on November 24)	O.P.+ 3,051 mm (31 mm decrease since 16:00 on November 24)	O.P.+ 2,927 mm (9 mm increase since 16:00 on November 24)	O.P.+ 2,867 mm (8 mm increase since 16:00 on November 24)
	Water level of Reactor Building	O.P.+ 3,969 mm (6 mm decrease since 16:00 on November 24)	O.P.+ 3,149 mm (31 mm decrease since 16:00 on November 24)	O.P.+ 3,005 mm (9 mm increase since 16:00 on November 24)	O.P.+ 2,870 mm (4 mm increase since 16:00 on November 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,103 mm (Increase from initial level:5,320 mm, 1 mm increase since 16:00 on November 24) O.P.+ 2,207 mm (Increase from initial level:2,933 mm, 29 mm decrease since 16:00 on November 24) O.P.+ 4,416 mm (Water level from floor:620 mm, 4 mm increase since 16:00 on November 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:44 on November 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:23 on November 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.