

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 25)**

Water Level of the accumulated water (at 16:00 on November 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,016 mm (24 mm decrease since 7:00 on November 25)	O.P.+ 2,896 mm (6 mm increase since 7:00 on November 25)	—
	Water level of Turbine Building	O.P.+ 2,749 mm (3 mm increase since 7:00 on November 25)	O.P.+ 3,027 mm (24 mm decrease since 7:00 on November 25)	O.P.+ 2,928 mm (1 mm increase since 7:00 on November 25)	O.P.+ 2,873 mm (6 mm increase since 7:00 on November 25)
	Water level of Reactor Building	O.P.+ 3,967 mm (2 mm decrease since 7:00 on November 25)	O.P.+ 3,135 mm (14 mm decrease since 7:00 on November 25)	O.P.+ 3,012 mm (7 mm increase since 7:00 on November 25)	O.P.+ 2,874 mm (4 mm increase since 7:00 on November 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,109 mm (Increase from initial level:5,326 mm, 6 mm increase since 7:00 on November 25) O.P.+ 2,194 mm (Increase from initial level:2,920 mm, 13 mm decrease since 7:00 on November 25) O.P.+ 4,419 mm (Water level from floor:623 mm, 3 mm increase since 7:00 on November 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:44 on November 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:23 on November 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

For quick publication of the data of water level, values are provided as reference values.