

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 26)**

Water Level of the accumulated water (at 7:00 on November 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,983 mm (33 mm decrease since 16:00 on November 25)	O.P.+ 2,905 mm (9 mm increase since 16:00 on November 25)	—
	Water level of Turbine Building	O.P.+ 2,753 mm (4 mm increase since 16:00 on November 25)	O.P.+ 3,002 mm (25 mm decrease since 16:00 on November 25)	O.P.+ 2,940 mm (12 mm increase since 16:00 on November 25)	O.P.+ 2,881 mm (8 mm increase since 16:00 on November 25)
	Water level of Reactor Building	O.P.+ 3,969 mm (2 mm increase since 16:00 on November 25)	O.P.+ 3,109 mm (26 mm decrease since 16:00 on November 25)	O.P.+ 3,025 mm (13 mm increase since 16:00 on November 25)	O.P.+ 2,883 mm (9 mm increase since 16:00 on November 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,111 mm (Increase from initial level:5,328 mm, 2 mm increase since 16:00 on November 25) O.P.+ 2,167 mm (Increase from initial level:2,893 mm, 27 mm decrease since 16:00 on November 25) O.P.+ 4,424 mm (Water level from floor:628 mm, 5 mm increase since 16:00 on November 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:44 on November 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:23 on November 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.