

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 28)**

Water Level of the accumulated water (at 7:00 on November 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,875 mm (34 mm decrease since 16:00 on November 27)	O.P.+ 2,933 mm (6 mm increase since 16:00 on November 27)	—
	Water level of Turbine Building	O.P.+ 2,765 mm (5 mm increase since 16:00 on November 27)	O.P.+ 2,908 mm (29 mm decrease since 16:00 on November 27)	O.P.+ 2,969 mm (10 mm increase since 16:00 on November 27)	O.P.+ 2,904 mm (7 mm increase since 16:00 on November 27)
	Water level of Reactor Building	O.P.+ 3,952 mm (5 mm decrease since 16:00 on November 27)	O.P.+ 3,016 mm (24 mm decrease since 16:00 on November 27)	O.P.+ 3,053 mm (8 mm increase since 16:00 on November 27)	O.P.+ 2,901 mm (4 mm increase since 16:00 on November 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,123 mm (Increase from initial level:5,340 mm, 2 mm increase since 16:00 on November 27) O.P.+ 2,118 mm (Increase from initial level:2,844 mm, 21 mm decrease since 16:00 on November 27) O.P.+ 4,437 mm (Water level from floor:641 mm, 4 mm increase since 16:00 on November 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:44 on November 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:16 on November 28 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. * At 8:16 AM on November 28, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.