

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 29)**

Water Level of the accumulated water (at 16:00 on November 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,845 mm (20 mm increase since 7:00 on November 29)	O.P.+ 2,934 mm (10 mm decrease since 7:00 on November 29)	—
	Water level of Turbine Building	O.P.+ 2,771 mm (3 mm increase since 7:00 on November 29)	O.P.+ 2,883 mm (19 mm increase since 7:00 on November 29)	O.P.+ 2,956 mm (23 mm decrease since 7:00 on November 29)	O.P.+ 2,916 mm (1 mm increase since 7:00 on November 29)
	Water level of Reactor Building	O.P.+ 3,921 mm (10 mm decrease since 7:00 on November 29)	O.P.+ 2,969 mm (3 mm decrease since 7:00 on November 29)	O.P.+ 3,050 mm (15 mm decrease since 7:00 on November 29)	O.P.+ 2,914 mm (4 mm increase since 7:00 on November 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,187 mm (Increase from initial level:5,404 mm, 1 mm increase since 7:00 on November 29) O.P.+ 2,253 mm (Increase from initial level:2,979 mm, 10 mm increase since 7:00 on November 29) O.P.+ 4,272 mm (Water level from floor:476 mm, 4 mm increase since 7:00 on November 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 9:44 on November 22 to 9:30 on November 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:40 on November 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.