

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 5)**

| | | | | | |
|---|---|--|--|---|---|
| Water Level of the accumulated water (at 7:00 on December 5) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 2,873 mm (38 mm decrease since 16:00 on December 4) | O.P.+ 2,881 mm (9 mm increase since 16:00 on December 4) | — |
| | Water level of Turbine Building | O.P.+ 2,786 mm (1 mm increase since 16:00 on December 4) | O.P.+ 2,905 mm (35 mm decrease since 16:00 on December 4) | O.P.+ 2,914 mm (11 mm increase since 16:00 on December 4) | O.P.+ 2,855 mm (7 mm increase since 16:00 on December 4) |
| | Water level of Reactor Building | O.P.+ 3,868 mm (17 mm decrease since 16:00 on December 4) | O.P.+ 3,022 mm (24 mm decrease since 16:00 on December 4) | O.P.+ 2,995 mm (10 mm increase since 16:00 on December 4) | O.P.+ 2,855 mm (5 mm increase since 16:00 on December 4) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,225 mm (Increase from initial level:5,442 mm, 2 mm increase since 16:00 on December 4) O.P.+ 2,678 mm (Increase from initial level:3,404 mm, 68 mm increase since 16:00 on December 4) O.P.+ 4,310 mm (Water level from floor:514 mm, 3 mm increase since 16:00 on December 4) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:53 on December 2) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:51 on December 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | * Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building. * Since 3:35 PM on December 3, we have been transferring water which has been pumped up for a trial from the well point installed at the east side of Unit 2, 3 (coactive pump-up by drain facility) to the Unit 2 Turbine Building. | | | | |

※ For quick publication of the data of water level, values are provided as reference values.