

Revised Version

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 9)**

\* The underlined part has corrected on December 18, 2013.

Water Level of the accumulated water (at 7:00 on December 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,671 mm (33 mm decrease since 16:00 on December 8)	O.P.+ 2,934 mm (8 mm increase since 16:00 on December 8)	—
	Water level of Turbine Building	O.P.+ 2,542 mm (No change since 16:00 on December 8)	O.P.+ 2,734 mm (29 mm decrease since 16:00 on December 8)	O.P.+ 2,969 mm (8 mm increase since 16:00 on December 8)	O.P.+ 2,904 mm (7 mm increase since 16:00 on December 8)
	Water level of Reactor Building	O.P.+ 3,761 mm (18 mm decrease since 16:00 on December 8)	O.P.+ 2,857 mm (25 mm decrease since 16:00 on December 8)	O.P.+ 3,057 mm (7 mm increase since 16:00 on December 8)	O.P.+ 2,900 mm (7 mm increase since 16:00 on December 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,246 mm (Increase from initial level:5,463 mm, 1 mm increase since 16:00 on December 8) O.P.+ 3,242 mm (Increase from initial level:3,968 mm, 98 mm increase since 16:00 on December 8) O.P.+ 4,337 mm (Water level from floor:541 mm, 4 mm increase since 16:00 on December 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:53 on December 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:27 on November 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:51 on December 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.