Revised Version

Situation of water level, transfer and treatment of the accumulated water * The underlined part has corrected on December 18, 2013.

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on December 10)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,726 mm (60 mm increase since 16:00 on December 9)	O.P.+ 2,949 mm (10 mm increase since 16:00 on December 9)	_
	Water level of Turbine Building	O.P.+ 2,547 mm (2 mm increase since 16:00 on December 9)	O.P.+ 2,779 mm (51 mm increase since 16:00 on December 9)	O.P.+ 2,989 mm (14 mm increase since 16:00 on December 9)	O.P.+ 2,919 mm (10 mm increase since 16:00 on December 9)
	Water level of Reactor Building	O.P.+ 3,742 mm (8 mm decrease since 16:00 on December 9)	O.P.+ 2,868 mm (23 mm increase since 16:00 on December 9)	O.P.+ 3,077 mm (12 mm increase since 16:00 on December 9)	O.P.+ 2,913 mm (9 mm increase since 16:00 on December 9)
	Water level of each building in the Centralized Radiation Waste	Process Main Building	O.P.+ 4.255 mm (Increase from initial level:5,472 mm, 2 mm decrease since 16:00 on December 9)		
		High Temperature Incinerator Building	O.P.+ 2,802 mm (Increase from initial level:3,528 mm, 426 mm decrease since 16:00 on December 9)		
	Treatment Facility	On-site Bunker Building	O.P.+ 4,346 mm (Water level from floor:550 mm, 7 mm increase since 16:00 on December 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	_	_
		Unit 5 and 6			
		_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:12 on November 6 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:51 on December 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump- up by drain facility) to the Unit 2 Turbine Building.				

% For quick publication of the data of water level, values are provided as reference values.