

Revised Version

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 13)**

* The underlined part has corrected on December 18, 2013.

Water Level of the accumulated water (at 7:00 on December 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,948 mm (39 mm increase since 16:00 on December 12)	O.P.+ 2,964 mm (14 mm decrease since 16:00 on December 12)	—
	Water level of Turbine Building	O.P.+ 2,548 mm (1 mm decrease since 16:00 on December 12)	O.P.+ 2,968 mm (31 mm increase since 16:00 on December 12)	O.P.+ 2,977 mm (54 mm decrease since 16:00 on December 12)	O.P.+ 2,954 mm (No change since 16:00 on December 12)
	Water level of Reactor Building	O.P.+ 3,776 mm (8 mm increase since 16:00 on December 12)	O.P.+ 3,052 mm (32 mm increase since 16:00 on December 12)	O.P.+ 3,079 mm (42 mm decrease since 16:00 on December 12)	O.P.+ 2,949 mm (1 mm increase since 16:00 on December 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,243 mm (Increase from initial level:5,460 mm, 21 mm decrease since 16:00 on December 12) O.P.+ 1,911 mm (Increase from initial level:2,637 mm, 24 mm increase since 16:00 on December 12) O.P.+ 4,369 mm (Water level from floor:573 mm, 4 mm increase since 16:00 on December 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 17:45 on December 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:00 on December 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:31 on December 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.