

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 18)**

Water Level of the accumulated water (at 7:00 on December 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,117 mm (57 mm decrease since 16:00 on December 17)	O.P.+ 2,824 mm (6 mm increase since 16:00 on December 17)	—
	Water level of Turbine Building	O.P.+ 2,553 mm (No change since 16:00 on December 17)	O.P.+ 3,110 mm (50 mm decrease since 16:00 on December 17)	O.P.+ 2,849 mm (59 mm increase since 16:00 on December 17)	O.P.+ 2,805 mm (12 mm decrease since 16:00 on December 17)
	Water level of Reactor Building	O.P.+ 3,902 mm (10 mm increase since 16:00 on December 17)	O.P.+ 3,232 mm (30 mm decrease since 16:00 on December 17)	O.P.+ 2,927 mm (64 mm increase since 16:00 on December 17)	O.P.+ 2,839 mm (15 mm decrease since 16:00 on December 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,155 mm (Increase from initial level:5,372 mm, 171 mm decrease since 16:00 on December 17) O.P.+ 2,373 mm (Increase from initial level:3,099 mm, 306 mm increase since 16:00 on December 17) O.P.+ 4,408 mm (Water level from floor:612 mm, 6 mm increase since 16:00 on December 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on December 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 7:53 on December 16 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 7:31 on December 12 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 1:33 PM on September 7, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.