

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 24)**

Water Level of the accumulated water (at 7:00 on December 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,801 mm (49 mm decrease since 7:00 on December 23)	O.P.+ 2,953 mm (14 mm increase since 7:00 on December 23)	—
	Water level of Turbine Building	O.P.+ 2,617 mm (13 mm increase since 7:00 on December 23)	O.P.+ 2,849 mm (41 mm decrease since 7:00 on December 23)	O.P.+ 2,990 mm (15 mm increase since 7:00 on December 23)	O.P.+ 2,921 mm (13 mm increase since 7:00 on December 23)
	Water level of Reactor Building	O.P.+ 4,081 mm (36 mm decrease since 7:00 on December 23)	O.P.+ 2,970 mm (30 mm decrease since 7:00 on December 23)	O.P.+ 3,080 mm (19 mm increase since 7:00 on December 23)	O.P.+ 2,915 mm (13 mm increase since 7:00 on December 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,049 mm (Increase from initial level:5,266 mm, 3 mm increase since 7:00 on December 23) O.P.+ 1,877 mm (Increase from initial level:2,603 mm, 75 mm decrease since 7:00 on December 23) O.P.+ 4,457 mm (Water level from floor:661 mm, 9 mm increase since 7:00 on December 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on December 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:08 on December 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 12:51 PM on December 18, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.