

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 25)**

Water Level of the accumulated water (at 7:00 on December 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,766 mm (35 mm decrease since 7:00 on December 24)	O.P.+ 2,966 mm (13 mm increase since 7:00 on December 24)	—
	Water level of Turbine Building	O.P.+ 2,629 mm (12 mm increase since 7:00 on December 24)	O.P.+ 2,819 mm (30 mm decrease since 7:00 on December 24)	O.P.+ 3,001 mm (11 mm increase since 7:00 on December 24)	O.P.+ 2,934 mm (13 mm increase since 7:00 on December 24)
	Water level of Reactor Building	O.P.+ 4,031 mm (50 mm decrease since 7:00 on December 24)	O.P.+ 2,940 mm (30 mm decrease since 7:00 on December 24)	O.P.+ 3,092 mm (12 mm increase since 7:00 on December 24)	O.P.+ 2,928 mm (13 mm increase since 7:00 on December 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,060 mm (Increase from initial level:5,277 mm, 11 mm increase since 7:00 on December 24) O.P.+ 1,807 mm (Increase from initial level:2,533 mm, 70 mm decrease since 7:00 on December 24) O.P.+ 4,463 mm (Water level from floor:667 mm, 6 mm increase since 7:00 on December 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:20 on December 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:08 on December 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 12:51 PM on December 18, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.