

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 6)

Water Level of the accumulated water (at 7:00 on January 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,872 mm (55 mm decrease since 7:00 on January 5)	O.P.+ 2,838 mm (12 mm increase since 7:00 on January 5)	—
	Water level of Turbine Building	O.P.+ 2,682 mm (2 mm increase since 7:00 on January 5)	O.P.+ 2,904 mm (47 mm decrease since 7:00 on January 5)	O.P.+ 2,880 mm (14 mm increase since 7:00 on January 5)	O.P.+ 2,816 mm (12 mm increase since 7:00 on January 5)
	Water level of Reactor Building	O.P.+ 3,924 mm (25 mm decrease since 7:00 on January 5)	O.P.+ 3,040 mm (45 mm decrease since 7:00 on January 5)	O.P.+ 2,963 mm (16 mm increase since 7:00 on January 5)	O.P.+ 2,817 mm (10 mm increase since 7:00 on January 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,173 mm (Increase from initial level:5,390 mm, 2 mm increase since 7:00 on January 5) O.P.+ 1,511 mm (Increase from initial level:2,237 mm, 13 mm decrease since 7:00 on January 5) O.P.+ 4,334 mm (Water level from floor:538 mm, 6 mm increase since 7:00 on January 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:34 on December 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:54 on December 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* Since 12:51 PM on December 18, we have been transferring water which has been pumped up from the well point installed at the east side of Unit 2 Turbine Building (coactive pump-up by drain facility) to the Unit 2 Turbine Building.				

※ For quick publication of the data of water level, values are provided as reference values.