

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 7)

Water Level of the accumulated water (at 7:00 on January 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,819 mm (53 mm decrease since 7:00 on January 6)	O.P.+ 2,849 mm (11 mm increase since 7:00 on January 6)	—
	Water level of Turbine Building	O.P.+ 2,685 mm (3 mm increase since 7:00 on January 6)	O.P.+ 2,860 mm (44 mm decrease since 7:00 on January 6)	O.P.+ 2,889 mm (9 mm increase since 7:00 on January 6)	O.P.+ 2,826 mm (10 mm increase since 7:00 on January 6)
	Water level of Reactor Building	O.P.+ 3,890 mm (34 mm decrease since 7:00 on January 6)	O.P.+ 2,996 mm (44 mm decrease since 7:00 on January 6)	O.P.+ 2,977 mm (14 mm increase since 7:00 on January 6)	O.P.+ 2,824 mm (7 mm increase since 7:00 on January 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,176 mm (Increase from initial level:5,393 mm, 3 mm increase since 7:00 on January 6) O.P.+ 1,500 mm (Increase from initial level:2,226 mm, 11 mm decrease since 7:00 on January 6) O.P.+ 4,340 mm (Water level from floor:544 mm, 6 mm increase since 7:00 on January 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:34 on December 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 7 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:00 AM on January 7, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.