

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 9)**

Water Level of the accumulated water (at 7:00 on January 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,012 mm (110 mm increase since 7:00 on January 8)	O.P.+ 2,795 mm (26 mm decrease since 7:00 on January 8)	—
	Water level of Turbine Building	O.P.+ 2,684 mm (1 mm increase since 7:00 on January 8)	O.P.+ 3,019 mm (89 mm increase since 7:00 on January 8)	O.P.+ 2,781 mm (45 mm decrease since 7:00 on January 8)	O.P.+ 2,797 mm (20 mm decrease since 7:00 on January 8)
	Water level of Reactor Building	O.P.+ 3,885 mm (20 mm increase since 7:00 on January 8)	O.P.+ 3,126 mm (96 mm increase since 7:00 on January 8)	O.P.+ 2,870 mm (47 mm decrease since 7:00 on January 8)	O.P.+ 2,818 mm (9 mm decrease since 7:00 on January 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,188 mm (Increase from initial level:5,405 mm, 6 mm increase since 7:00 on January 8) O.P.+ 1,770 mm (Increase from initial level:2,496 mm, 51 mm increase since 7:00 on January 8) O.P.+ 4,352 mm (Water level from floor:556 mm, 7 mm increase since 7:00 on January 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on January 8 to 15:00 on January 8)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:54 on January 7   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.