

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 10)**

Water Level of the accumulated water (at 7:00 on January 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,089 mm (77 mm increase since 7:00 on January 9)	O.P.+ 2,760 mm (35 mm decrease since 7:00 on January 9)	—
	Water level of Turbine Building	O.P.+ 2,686 mm (2 mm increase since 7:00 on January 9)	O.P.+ 3,084 mm (65 mm increase since 7:00 on January 9)	O.P.+ 2,737 mm (44 mm decrease since 7:00 on January 9)	O.P.+ 2,770 mm (27 mm decrease since 7:00 on January 9)
	Water level of Reactor Building	O.P.+ 3,935 mm (50 mm increase since 7:00 on January 9)	O.P.+ 3,179 mm (53 mm increase since 7:00 on January 9)	O.P.+ 2,822 mm (48 mm decrease since 7:00 on January 9)	O.P.+ 2,802 mm (16 mm decrease since 7:00 on January 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,191 mm (Increase from initial level:5,408 mm, 3 mm increase since 7:00 on January 9) O.P.+ 1,830 mm (Increase from initial level:2,556 mm, 60 mm increase since 7:00 on January 9) O.P.+ 4,357 mm (Water level from floor:561 mm, 5 mm increase since 7:00 on January 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:54 on January 7   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.