

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 14)**

Water Level of the accumulated water (at 7:00 on January 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,091 mm (61 mm decrease since 7:00 on January 13)	O.P.+ 2,707 mm (16 mm increase since 7:00 on January 13)	—
	Water level of Turbine Building	O.P.+ 2,447 mm (243 mm decrease since 7:00 on January 13)	O.P.+ 3,083 mm (53 mm decrease since 7:00 on January 13)	O.P.+ 2,741 mm (23 mm increase since 7:00 on January 13)	O.P.+ 2,694 mm (2 mm increase since 7:00 on January 13)
	Water level of Reactor Building	O.P.+ 4,010 mm (No change since 7:00 on January 13)	O.P.+ 3,212 mm (55 mm decrease since 7:00 on January 13)	O.P.+ 2,817 mm (34 mm increase since 7:00 on January 13)	O.P.+ 2,726 mm (11 mm decrease since 7:00 on January 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,205 mm (Increase from initial level:5,422 mm, 3 mm increase since 7:00 on January 13) O.P.+ 2,076 mm (Increase from initial level:2,802 mm, 65 mm increase since 7:00 on January 13) O.P.+ 4,378 mm (Water level from floor:582 mm, 6 mm increase since 7:00 on January 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:30 on January 13 to 16:42 on January 13)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on January 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:54 on January 7   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.