

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 15)**

Water Level of the accumulated water (at 7:00 on January 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,052 mm (39 mm decrease since 7:00 on January 14)	O.P.+ 2,724 mm (17 mm increase since 7:00 on January 14)	—
	Water level of Turbine Building	O.P.+ 2,447 mm (No change since 7:00 on January 14)	O.P.+ 3,053 mm (30 mm decrease since 7:00 on January 14)	O.P.+ 2,761 mm (20 mm increase since 7:00 on January 14)	O.P.+ 2,707 mm (13 mm increase since 7:00 on January 14)
	Water level of Reactor Building	O.P.+ 3,991 mm (19 mm decrease since 7:00 on January 14)	O.P.+ 3,175 mm (37 mm decrease since 7:00 on January 14)	O.P.+ 2,834 mm (17 mm increase since 7:00 on January 14)	O.P.+ 2,727 mm (1 mm increase since 7:00 on January 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,209 mm (Increase from initial level:5,426 mm, 4 mm increase since 7:00 on January 14) O.P.+ 2,142 mm (Increase from initial level:2,868 mm, 66 mm increase since 7:00 on January 14) O.P.+ 4,383 mm (Water level from floor:587 mm, 5 mm increase since 7:00 on January 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on January 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:54 on January 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.