

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 17)**

Water Level of the accumulated water (at 7:00 on January 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,981 mm (43 mm decrease since 7:00 on January 16)	O.P.+ 2,748 mm (12 mm increase since 7:00 on January 16)	—
	Water level of Turbine Building	O.P.+ 2,448 mm (1 mm decrease since 7:00 on January 16)	O.P.+ 2,994 mm (33 mm decrease since 7:00 on January 16)	O.P.+ 2,790 mm (15 mm increase since 7:00 on January 16)	O.P.+ 2,730 mm (12 mm increase since 7:00 on January 16)
	Water level of Reactor Building	O.P.+ 3,943 mm (24 mm decrease since 7:00 on January 16)	O.P.+ 3,128 mm (27 mm decrease since 7:00 on January 16)	O.P.+ 2,863 mm (13 mm increase since 7:00 on January 16)	O.P.+ 2,742 mm (8 mm increase since 7:00 on January 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,227 mm (Increase from initial level:5,444 mm, 9 mm increase since 7:00 on January 16) O.P.+ 2,409 mm (Increase from initial level:3,135 mm, 24 mm increase since 7:00 on January 16) O.P.+ 4,393 mm (Water level from floor:597 mm, 5 mm increase since 7:00 on January 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on January 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:32 on January 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.