

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 20)**

Water Level of the accumulated water (at 7:00 on January 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,861 mm (17 mm decrease since 7:00 on January 19)	O.P.+ 2,743 mm (32 mm decrease since 7:00 on January 19)	—
	Water level of Turbine Building	O.P.+ 2,456 mm (1 mm increase since 7:00 on January 19)	O.P.+ 2,894 mm (14 mm decrease since 7:00 on January 19)	O.P.+ 2,751 mm (65 mm decrease since 7:00 on January 19)	O.P.+ 2,748 mm (6 mm decrease since 7:00 on January 19)
	Water level of Reactor Building	O.P.+ 3,849 mm (36 mm decrease since 7:00 on January 19)	O.P.+ 3,016 mm (32 mm decrease since 7:00 on January 19)	O.P.+ 2,837 mm (56 mm decrease since 7:00 on January 19)	O.P.+ 2,761 mm (4 mm increase since 7:00 on January 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,237 mm (Increase from initial level:5,454 mm, 2 mm increase since 7:00 on January 19) O.P.+ 2,917 mm (Increase from initial level:3,643 mm, 437 mm increase since 7:00 on January 19) O.P.+ 4,408 mm (Water level from floor:612 mm, 5 mm increase since 7:00 on January 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:12 on January 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:00 on December 17)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 19:21 on December 18 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:32 on January 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* From 9:55 AM on January 12 to 9:28 AM on January 19, 2014, accumulated water had been transferred from Unit 2 Turbine Building basement to Unit 3 Turbine Building basement.				

※ For quick publication of the data of water level, values are provided as reference values.